




TÜVRheinland®


DIN CERTCO

Genau. Richtig.

CERTIFICATE

Certificate holder	Techem Energy Services GmbH Hauptstr. 89 65760 Eschborn GERMANY
Product	Heat cost allocators - Appliances with electrical energy supply
Type, Model	FHKV radio 4 / EHKV vario 4
Testing basis	DIN EN 834:2017-02 Certification scheme Heat cost allocators (2017-04)
Mark of conformity	
Registration No.	295/25 E
Valid until	2030-01-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2025-04-16


Dipl.-Biol. Katharina Vehrung, M. Eng.
Certification Body





ANNEX

Certificate	295/25 E dated 2025-04-16
Technical Data	Type: Compact and remote sensor version Readout of measured values: decentral Basic conditions: 50 °C mid-level heating medium temperature Upper temperature limits stated t(max): 90 °C Compact device, 130 °C Remote sensor device Lower temperature limits stated t(min): 35 °C
Testing laboratory/ Inspection body	Universität Stuttgart Institut für Gebäudeenergetik, Thermotechnik und Energie- speicherung Pfaffenwaldring 6-6 a 70569 Stuttgart GERMANY
Test report(s)	SD15 H001 TE dated 2015-06-26 SD15 H001 TE K.1 dated 2016-01-15 SE21 H001 TE C.1 dated 2021-02-25 SK25 H002TE dated 2025-03-19

