

CERTIFICATE PT/24/GEN/0010/2


Certificate order no.	Test report reference:	Certificate issue date:	Certificate expiry date:
GZ-CERT241204525-01	GZES240801694102, GZES240801709202, GZES240901759602	2024-12-12	2026-12-12

License Holder:
FireAngel Safety Technology Limited
Vanguard Centre, Sir William Lyons Road, Coventry,
CV4 7EZ, United Kingdom

Manufacturing Plant:
Siterwell Electronics Co., Limited
No. 666 Qingfeng Road, Jiangbei District, Ningbo,
Zhejiang, China


Tested according to:
EN 50291-1:2018
EN 14604:2005
BS 5446-2:2003

Licensed Test Mark:



Performance Tested


- EN 14604:2005 + AC:2008 (for model 580200)
- EN 50291-1: 2018
- BS 5446-2: 2003



Certified Product:
Type designations: Multisensor Plus
Trademarks: 580200, 580250
Technical Data: FireAngel
See page 2

Remarks: 580200 is a smoke, carbon monoxide, heat combined alarm.
580250 is a carbon monoxide, heat combined alarm, not applied for EN 14604.

Certification Body
SGS Testing & Control Services Singapore Pte Ltd.


CY Mok
Certifier



Additional Information:

Technical Data:

2×3VDC CR17450E-N FDK lithium batteries parallel connected or 2×3VDC CR-AGZ Panasonic lithium batteries parallel connected.

10-year battery service life of the apparatus.

The apparatus is equipped with two alternative CO sensors: Figaro TGS5141-P00 or Pace NANO-3.

Software version: V5.0.0 (For Figaro CO sensor), V2.5.4 or V2.5.5 (For Pace CO sensor).

